


KEY	NOTE
1	EXISTING CEILING MOUNTED TROUGH TO BE DEMOLISHED.
2	EXISTING CEILING MOUNTED RECEPTACLE TO BE DEMOLISHED.
3	EXISTING LIGHTING TO REMAIN.
4	EXISTING LIGHT SWITCH TO BE RELOCATED TO COORDINATE WITH NEW DOOR SWING. TIE TO EXISTING LIGHT FIXTURES AND CIRCUIT.

- 1ST FLOOR LIGHTING DEMOLITION PLAN NOTES:
- DEMOLISH ALL ELECTRICAL CONDUCTORS AND CONDUIT BACK TO PANELBOARD FOR ALL DEVICES SHOWN ON THIS PLAN. MARK EXISTING UNUSED OVERCURRENT PROTECTION DEVICES AS "SPARE".
  - CONTRACTOR SHALL REUSE EXISTING FIRE ALARM DEVICES IF NOT DAMAGED DURING DEMOLITION.
  - CONTRACTOR SHALL NOT LEAVE ANY UNUSED ELECTRICAL DEVICES ABANDONED IN PLACE. ALL ELECTRICAL DEVICES MUST BE REMOVED.
  - EXISTING EQUIPMENT, SUCH AS LIGHTING FIXTURES, WIRING DEVICES, CONDUITS, ETC., SHOWN ON PLANS TO BE REMOVED COMPLETELY. CUT/CAP CONDUITS AT THE AREA OF WORK PERIMETER AND REMOVE CONDUIT WITHIN THE WORK AREA, DISCONNECT WIRING AT THE OVERCURRENT PROTECTIVE DEVICE AND REMOVE WIRING COMPLETELY FROM THE ABANDONED CONDUITS.
  - REMOVE ALL ACCESSIBLE ABANDONED WIRING OF ALL TYPES, OR CAP AND LABEL IN JUNCTION BOX FOR RE-USE, IN COMPLIANCE WITH THE NATIONAL ELECTRIC CODE.
  - MAINTAIN AND RESTORE ANY EXISTING SYSTEMS THAT WILL REMAIN IN USE DURING DEMOLITION OR CONSTRUCTION, IF INTERRUPTED. ALL CONDUITS AND CONDUCTORS PASSING THROUGH RENOVATED AREAS AND SERVING UNDISTURBED AREAS.

1 1ST FLOOR LIGHTING & FIRE ALARM DEMOLITION PLAN  
1/8" = 1'-0"

FULLY SPRINKLERED  
ISSUED FOR BID

CONSULTANTS:										PROJECT MANAGER:		Project Number 3627	Scale 1/8" = 1'-0"	Drawing Title 1ST FLOOR LIGHTING DEMOLITION PLAN	Project Title RENOVATE BUILDING 69	VA Project Number 542-CSI-203	Office of Facilities Management  
Project Manager BRAY MOONEY CONSULTING  410 E. 21 STREET CHESTER, PA 19013 Tel: (610) 872-3716		Architect WZG, STRUCTURAL FACILITIES SOLUTIONS  2520 RENAISSANCE BLVD., SUITE 110 KING OF PRUSSIA, PA 19406 Tel: (610) 270-0599	Structural Engineer WZG, STRUCTURAL CONSULTING ENGINEERS  180 W. RIDGE PIKE LIMERICK, PA 19468 Tel: (214) 329-5559	MEP/FP Engineer APOGEE CONSULTING GROUP  7330 CHAPEL HILL ROAD, SUITE 202 RALEIGH, NC 27606 Tel: (919) 859-7420	Civil Engineer GUIDON DESIGN  2453 N DELAWARE STREET INDIANAPOLIS, IN 46205 Tel: (317) 800-6386	Fire Protection Consultant HARRINGTON GROUP  7508 E. INDEPENDENCE BLVD., SUITE 116 CHARLOTTE, NC 28277 Tel: (704) 531-9777	Cost Estimator BRAY MOONEY CONSULTING  410 E. 21 STREET CHESTER, PA 19013 Tel: (610) 872-3716	Aquatic Consultant ATLANTIC AQUATIC ENGINEERING  1823 DEEP RUN ROAD PIPERSVILLE, PA 18947 Tel: (215) 766-0409	Approved: Project Director		Location 1400 Black Horse Hill, Coatesville, PA		Date 1/22/2014	Checked CGS/WCM	Drawn KLC	Drawing Number ED102 Dwg. 71 of 86	
Revisions		Date															